Temperature Transducers Model TE-211Y, TE-211Z, TE-213

TE-211Y, Z

- Temperature transducer utilizing 100 Ω Platinum RTD and 1,000 Ω Platinum RTD
- 24 VDC power input, 4-20 mA two wire loop signal output

TE-213

- Temperature transducer utilizing Integrated Circuit
- 12, 24 VDC power input, 0-5, 0-10 VDC, and 4-20 mA signal output available
- Supports four (4) wire power, signal configuration

GENERAL INFORMATION MAMAC SYSTEMS TEMPERATURE TRANSDUCERS

All sensing elements manufactured by MAMAC Systems, Inc. for the **TE-211** and **TE-213** are protected against moisture and other contaminants by means of a conformal coating process. The conformal coat is applied to the sensor and a portion of the lead wires creating a moisture proof seal. In addition to coating the sensor, the same urethane compound is used to seal the end of the probe where sensor lead wires exit, resulting in another barrier against harmful moisture. Without this protection, sensors may fail in a short condition due to condensation and other sources of moisture.

The **TE-211** and **TE-213** are available in different housings to cover applications of Space, Duct, Immersion, Duct Averaging, Outside Air and Strap-On.

Space Temperature: Polystyrene enclosure with internal wall separating the sensing element from the electronic circuit board.

Duct/Immersion Temperature: Sturdy NEMA-1 16 AWG steel enclosure houses the electronic circuit board. Available with 4", 6", 8" or 12" aluminum or series 300 stainless probe. Probe protrudes from the bottom of the enclosure and is affixed to the enclosure with a brass compression fitting. The bottom of the duct enclosure is gasketed for a tight seal to the duct work. The immersion sensor is equipped with a 1/4" NPT or 1/2" NPT thermowell fitting that can be screwed directly into the A-500 thermowell providing a rigid support to the transducer.

Duct Averaging: NEMA-1 16 AWG steel enclosure with 6 ft., 12 ft. or 24 ft. bendable aluminum 3/8" OD probe for averaging duct air temperature. The probe incorporates numerous encapsulated at equal distances across the length of the probe. The complete assembly acts as a single sensor and temperature change is averaged across the sensors. The probe can be easily bent to fit any size duct.

Outside Air: A weather proof enclosure with suitable sun shield can be easily screwed onto 1/2" conduit.

Strap-On: A NEMA-1 16 AWG steel enclosure is provided with 6 ft. of 18 AWG twisted shielded cable. The sensing element is housed in a 2" aluminum or stainless steel probe at the end of the cable suitable for being strapped onto a pipe or used in a remote application.



7400 Flying Cloud Drive • Minneapolis, MN 55344-3720 • USA 800-834-5116 • 952-835-1626 • Fax 952-829-5331 www.mamacsys.com

Baird House, Units 6&7 Pensnett Estate • Kingswinford West Midlands • DY6 7YA • United Kingdom 01384-271113 • Fax 01384-271114 4 Arminger Court, Unit 2 Holden Hill ● S.A. 5088 ● Australia 08-8395-4333 ● Fax 08-8395-4433 155 McIntosh Drive, Units 5&6 ● Markham Ontario ● L3R ON6 ● Canada 905-474-9215 ● Fax 905-474-0876 No. 22 Lorong 21A Geylang #11-02 Chin Hin Hang Building Singapore ● 388421 65-3927273 ● Fax 65-3927276

TE-211Y, TE-211Z, TE-213

MORE ABOUT TE -211Y, -211Z

The RTD and transmitter are matched and calibrated as a complete assembly in a temperature chamber against a NIST traceability calibrated standard. The final accuracy is verified with a three (3) point calibration check against the standard over the specified temperature range. The transmitter is equipped with non-interacting zero and span adjustment trimmers for site calibration and is reverse polarity protected against accidental mis-wiring. The transmitter assembly conforms to a ANSI S50.1 Type 2 Class U circuit.


MORE ABOUT THE TE-213

Signal conditioning is performed by industrial quality integrated circuits to provide a true linear output. The circuit is factory calibrated but zero and span trimmers are provided to adjust the output if necessary. Output accuracy is not affected by long wire runs or electrical noise. The TE-213 provides an analog output linear and proportional to the calibrated temperature range. The integrated circuit and transmitter are calibrated as a complete assembly in a temperature chamber using a NIST traceable calibrated standard. The final accuracy of ±0.5°F is verified with a three (3) point check against the standard over the specified temperature range.

ORDERING INFORMATION - TE-211

MODEL	ENCLOSURE	PROBE LENGTH	PROBE MATERIAL	WELL FITTING	VOLTAGE IN	SIGNAL OUTPUT	RANGE
TE-211-Y for 100 Ω Sensor	(A) Space (B) Duct (C) Immersion	(A) 4 Inches (B) 6 Inches (C) 8 Inches	(1) Aluminum (2) Stainless Steel	(A) Brass 1/4" NPT (B) Brass 1/2"	(1) 24 VDC	(E) 4–20 MA 2 wire	(1) 50 T 85F (2) 40 T 140F (3) -30 T 130F
TE-211-Z for 1,000 Ω Sensor	(D) Duct Ave (E) Remote Probe Strap	(D) 12 Inches (E) 2 Inches (F) 6 Feet (G) 12 Feet	(3) Custom	NPT (C) Custom			(4) 0 T 100F (5) 100 T 250F (6) 0 T 250F
	(F) Outdoor (G) Custom	(H) 24 Feet (I) Custom					(7) Custom
			•	•		•	•
USE THIS NUMBER ORD	-				1	E	

ORDERING INFORMATION - TE-213



TE-211Y, TE-211Z, TE-213

SPECIFICATIONS:

Accuracy*: ± 0.50° F FS; Linearity: ± 0.05° F; Repeatability: ± 0.01° F; Transmitter Er-Accuracy:

ror: better than ±.01% span.

Ambient Temperature: -30° F to 250° F; Humidity: (10-95%) Non-condensing; Maxi-Environmental:

mum Temperature Span: 250° F; Minimum Temperature Span: 35° F

Stability: Stability Factor Over T (rates of drift): better than 10,000 hours @400C; Sensor Sta-

bility: .07 ohms per 10,000 hours @ 400C

Supply Voltage:

TE-211: 13 to 28 VDC. Can go down to 12 VDC, but max input impedance is 250 ohms (250 ohms x 20 mA = 5 VDC). **TE-213:** 18 VAC, VDC or greater; 24 VDC, 24

VAC, 115 VAC, 12 VDC* (maximum input impedance 250Ω)

TE-211: 4 to 20 mA (proportional to range) TE-213: 0-1 VDC, 0-5 VDC, 0-10 VDC, Output:


4-20 MA, 4-10 MA 2 wire, 1-50HKz AFCP


Current Draw: 50 mA


* Accuracy of Duct Averaging Transducer is ±3F

DIMENSIONS:


Space Temperature Enclosure Dimensions:










Duct, Immersion, Duct Averaging Enclosure Dimensions:









Outdoor Air Enclosure Dimensions:






TOP VIEW



TEMPERATURE TRANSDUCER

ZERO AND SPAN TRIMMER POSITIONS



TE-211 Board, Wall Mount Figure 1

TE-211 Board, All Other Versions Figure 2

TE-213 Board, All Versions Figure 3



Please Note: "Z" designates the zero trimmer potentiometer, "S" designates the span trimmer potentiometer. These devices are calibrated in our factory using NIST certified temperature calibration equipment. **There should be no requirement for field calibration.**

Please Note: Shown with terminal blocks removed!

TYPICAL APPLICATIONS (wiring diagrams)

Figure 1 and Figure 2 illustrate typical wiring diagrams for the mA output temperature transducer.

Figure 1 - Wiring for mA Temperature Transducers with an External DC Power Supply




Figure 2 - Wiring for mA Output Transducers where the Controller or Meter has an Internal DC Power Supply




Figure 3 and Figure 4 illustrate typical wiring diagrams for the VDC output temperature transducer.

Figure 3 - Wiring for VDC Temperature Transducers When Applied with External AC Supply





Figure 4 - Wiring for VDC Temperature Transducers When Applied with External DC Supply



MAMAC SYSTEMS

8189 Century Boulevard • Minneapolis, MN 55317-8002 • USA 800-843-5116 • 952-556-4900 • Fax 952-556-4997 sales@mamacsys.com • www.mamacsys.com

Baird House, Units 6&7
Pensnett Estate • Kingswinford
West Midlands • DY6 7YA • United Kingdom
01384-271113 • Fax 01384-271114

4 Arminger Court, Unit 2 Holden Hill • S.A. 5088 • Australia 08-8395-4333 • Fax 08-8395-4433 155 McIntosh Drive, Units 5&6 • Markham Ontario • L3R ON6 • Canada 905-474-9215 • Fax 905-474-0876 No. 22 Lorong 21A Geylang # 11-02 Prosper Industrial Building Singapore • 388421 656-3927273 • Fax 656-3927276